**From:** Eric Pottenger
**To:** "David Lorei"
**Cc:** Teresa Barnes
**Subject:** RE: LaRosa"s - Hamilton Middletown Road
**Date:** Thursday, August 30, 2018 8:24:06 AM

---

David,

I understand this site was previously evaluated and detention was addressed with an existing off-site detention basin however, Water Quality will need to be addressed. With a small area, a mechanical treatment device may be your best option.

Sincerely,
Eric

**Eric J. Pottenger**
Development Services Manager
pottengere@bceo.org

**Butler County Engineer's Office**
1921 Fairgrove Avenue (SR4)
Hamilton, OH 45011-1965
D: 513.785.4121 | T: 513.867.5744
M: 513.678.6325 | F: 513.867.5849
www.bceo.org

---

**From:** David Lorei [mailto:dlorei@abercrombie-associates.com]
**Sent:** Wednesday, August 29, 2018 3:56 PM
**To:** Eric Pottenger
**Subject:** LaRosa's - Hamilton Middletown Road

Eric,

We are currently designing a parking lot extension for the exisitng LaRosa's on Hamilton Middletown Road. I have attached a .pdf of the Layout Plan.

My question is in regards to storm water management. As you will see the total on-site drainage area is approximately 0.32Ac. Does the County have a storm water waiver in regards to smaller sites?

I will call in the morning to discuss.

Thanks

***David Lorei, P.E.***
***Project Manager***

Abercrombie & Associates, Inc.
Civil Engineering + Surveying

Colerain Professional Center, Suite 120
3377 Compton Road
Cincinnati, Ohio 45251
Phone: (513) 385-5757 ~ Fax: (513) 245-5161
www.abercrombie-associates.com