From:	Mitch Fry
To:	Teresa Barnes; "Mork Lachniet"
Cc:	Eric Pottenger; Jody Bohn
Subject:	RE: The Oaks (Keefe Property tracts 2 & 3)
Date:	Friday, January 13, 2017 4:25:29 PM

Teresa,
I am more than happy to meet and have asked Coppage to attend as well. I am in Columbus on Monday, but I am free any time after 9:30 on Tuesday. Let me know what works for you and we can meet to discuss. Please let me know. Thanks
Mitch

From: Teresa Barnes [mailto:BarnesT@bceo.org]
Sent: Friday, January 13, 2017 3:26 PM
To: 'Mork Lachniet' <morklachniet@bayerbecker.com>; Mitch Fry <mfry@Steiner.com>
Cc: Eric Pottenger <PottengerE@bceo.org>; Jody Bohn <BohnJ@stormwaterdistrict.org>
Subject: The Oaks (Keefe Property tracts 2 & 3)

Mitch

We have received a complaint from a resident downstream.
The pictures he sent from yesterday show a very sediment laden stream through his backyard.
Jody and I performed a site inspection today (January 13, 2017) and discovered that, while there is silt fence installed; it is installed in the wrong location.
Given the current state of construction, all of the site water, for the commercial area, is graded to enter the side of the box culvert.
While some RCP has been placed in the channel on both sides of the box culvert, the rock provided very little erosion and sediment protection.
At this point in time, additional rock check dams, silt fence and or mulch berms, etc need to be installed to prevent the sediment from leaving the site.
I am willing to meet you on-site to discuss the issues, let me know a time that works for you.
THANKS

Teresa

Teresa K. Barnes, P.E., CPESC
DESIGN ENGINEER

1921 Fairgrove Avenue
Hamilton, OH 45011

513-785-4142
Fax 513-867-8549

barnest@bceo.org

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit http://www.symanteccloud.com