From: Jonathan Wuchner
To: Teresa Barnes; Joe Haubert
Subject: RE: 7940 SEWARD ROAD AS-BUILT
Date: Wednesday, January 16, 2019 12:09:16 PM

Thanks, for update Teresa. I have copied Joe Haubert with Kleingers on the email, he is review internally but there appears to have been a revision or change to the drawings and you may possibly have an old drawing. Joe will provided an update once he has confirmation.

Thanks

Jonathan Wuchner
Project Superintendent

From: Teresa Barnes <BarnesT@bceo.org>
Sent: Wednesday, January 16, 2019 11:42 AM
To: Jonathan Wuchner <Jonathan.Wuchner@dukerealty.com>
Subject: RE: 7940 SEWARD ROAD AS-BUILT

CAUTION EXTERNAL EMAIL

DO NOT open attachments or click on links from unknown senders or unexpected emails

Jonathan

I had a telephone conversation with Matt.
To try to summarize – the storm drain pipe system appears good.
However, the information for the detention basin is incomplete and there appears to be some slight discrepancies from the storm drain report I have on file to the one on the drawings.
I do not think that things are major issues – but we do need some clarification before releasing the CO.

Matt is going to have them run a new detention basin page that shows the areas and volumes per each elevation – that then shows the as-built total.

In addition, I questioned why the report that I have shows a 5.5 inch water quality orifice and the as-builts indicate a 6-inch. Matt was going to verify the difference.

THANKS
Teresa

Teresa K. Barnes, P.E., CPESC
DESIGN ENGINEER
1921 Fairgrove Avenue
Hamilton, OH 45011
513-785-4142
Fax 513-867-8549
barnest@bceo.org

From: Jonathan Wuchner [mailto:Jonathan.Wuchner@dukerealty.com]
Sent: Monday, January 14, 2019 10:45 AM
To: Teresa Barnes
Cc: Sean Jeanes; Matt Weller
Subject: FW: 7940 SEWARD ROAD AS-BUILT

Good Morning Teresa
Per our conversation this morning, please reply to this email once you have reviewed the as-built drawing for 7940 Seward. Please let me know if you need anything further.
Thanks

Jonathan Wuchner
Project Superintendent

From: Matt Weller <matt@broncoex.com>
Sent: Wednesday, January 9, 2019 3:22 PM
To: Jonathan Wuchner <Jonathan.Wuchner@dukerealty.com>
Cc: Joe Kulifay <joe@broncoex.com>
Subject: Fw: 7940 SEWARD ROAD AS-BUILT

CAUTION EXTERNAL EMAIL
DO NOT open attachments or click on links from unknown senders or unexpected emails

Jonathan,

The following (attached) items were sent to Teresa at BCEO today at 3:13 PM. I will let you know should they require further information. This is the same format and layout of

information we sent to her for the last several projects we completed in the county (and they were approved).

I will let you know should she require any revisions or additional information,

Thank you,

Matt Weller
Bronco Excavating, Inc.
513-829-9880 x 114
513-617-8770 c

From: Matt Weller
Sent: Wednesday, January 9, 2019 3:11 PM
To: 'barnest@bceo.org'
Subject: 7940 SEWARD ROAD AS-BUILT STORM SEWER

Good Afternoon Teresa,

I have attached the as-built drawings for the Fairfield Logistics project located at 7940 Seward Road.

Attached to this email, you will find:

- page c300 (utility plan view redline)
- page c310 (profile view redline)
- page c502 (profile for cb105a redline)
- detention basin as-built (with proposed and redline data)

Please let me know if you require further information or if there is anything else you require for this project and I will make certain it gets done. Thank you for your assistance,

Matt Weller
Bronco Excavating, Inc.
513-829-9880 x 114
513-617-8770 c

CONFIDENTIALITY NOTICE: This e-mail message and all attachments transmitted with it may contain legally privileged and confidential information intended solely for the use of the addressee. If the reader of this message is not the intended recipient, you are hereby notified that any reading, dissemination, distribution, copying or other use of this message or its attachments is strictly prohibited. If you received this e-mail in error, please notify the sender immediately by telephone or e-mail and delete this message and all copies or backups thereof. Thank you for your cooperation.

CONFIDENTIALITY NOTICE: This e-mail message and all attachments transmitted with it may contain legally privileged and confidential information intended solely for the use of the addressee. If the reader of this message is not the intended recipient, you are hereby notified that any reading, dissemination, distribution, copying or other use of this message or its attachments is strictly prohibited. If you received this e-mail in error, please notify the sender immediately by telephone or e-mail and delete this message and all copies or backups thereof. Thank you for your cooperation.