From: Tim Greive
To: BarnesT@bceo.org
Cc: PottengerE@bceo.org
Subject: Re: Kyles Station Krogers
Date: Thursday, January 28, 2016 8:58:54 AM

Teresa

Can you approve the bond amount for the storm sewer system including the detention basin that is needed for the subdivision approval? I had sent the cost estimate to Eric earlier for the detention basin and the portion of the private storm sewer system that serves the subdivision.

Thank you

Tim

On 1/26/2016 11:29 AM, BarnesT@bceo.org wrote:

> Good Morning Tim
>
> I have had a chance to look through the response to my previous comment letter.
> At this point, in order to review the current proposed storm system, I will need an updated utility plan and a drainage area map.
> Note, the first page of the provided storm pipe calculations (pipes 1-4) appear to be at the intersection of Rt 4 and Kyles Station Rd. However, the calculations indicate a pipe size of 24-inches while the drawings sumbitted on 1-11-16 indicate a 30-inch pipe.
> In addition, once the building permit is applied for, a full set of construction drawings and calculations will be required, to ensure that we have a complete coordinated set.
> Let me know if you have any questions.
> THANKS
>
> Teresa

Teresa Barnes, P.E., CPESC
Design Engineer
Butler County Storm Water District
1921 Fairgrove Avenue
Hamilton, Ohio 45011

513-785-4142 Office
513-867-5849 Fax

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit http://www.symanteccloud.com

---

No virus found in this message.
Checked by AVG - www.avg.com
Version: 2016.0.7357 / Virus Database: 4522/11490 - Release Date: 01/26/16