

CHESTERWOOD RETIREMENT COMM. - TYLERSVILLE ROAD

<u>Received plans</u>	<u>Reviewed</u>	<u>Contact Eng.</u>	<u>Release Date</u>
9/10/96	9/11/96		

(Bayer & Becker Engineers)

Need construction details. Must have raised curb. Check the location of drive; has it shifted to the west? West Chester Plaza - pull file and check location of drive.

Sidewalk is approved.

9/19/96: Talked to Tim Dixon and advised him to get a r/w permit for right-in and right-out. They will also need a permit to install sidewalks. Note on sidewalk permit: Sidewalk must go around trees.

10/9/96: Issued r/w permit for right-in and right-out.

11/27/96: Jeff Wright with Union Township will send plans on the sidewalks. To date, Dixon has not applied for r/w permit for sidewalks.