From: Adrienne Rice
Sent: Thursday, April 22, 2021 3:07 PM
To: Eric Pottenger
Subject: Reynolds property
Attachments: IMG_5131.jpg; IMG_5132.jpg; IMG_5133.jpg; IMG_5134.jpg

---

Eric,

See pictures attached. They established a ditch line as discussed on either side of the driveway along the road. About a 6" drop from road edge. Swale is graded in the driveway minimum drop is currently 8" and asphalt will be 3" thick. The drive is pitched to the west and they will have a swale run down the west side of the driveway to the ditch.

Contact me with questions.

Regards,

Adrienne Rice
Storm Water/ Permit Inspector
ricea@bceo.org

Butler County Engineer's Office
1921 Fairgrove Avenue (SR4)
Hamilton, OH 45011-1965
D: 513.785.4119 | M: 513.571.7775 | F: 513.867.5849
www.bceo.org

From: Adrienne Rice <RiceA@bceo.org>
Sent: Thursday, April 22, 2021 2:58 PM
To: Adrienne Rice <RiceA@bceo.org>
Subject: Reynolds property

Get Outlook for iOS