From: Eric Pottenger
Sent: Monday, June 24, 2024 3:54 PM
To: bhellard@westchesteroh.org
Cc: Jeff.Frechtling@bcohio.us; kelly.chambers-taylor@bcohio.us
Subject: BZA 24-11 STACEY
Attachments: BZA 24-11 STACEY.pdf
BZA 24-11 STACEY - APPLICATION.pdf

Bryan,

See attached pertaining to this variance request. There is a 10-ft Easement on the north property line, containing an 8" sanitary sewer main. We recommend the applicant discuss with Butler County Water and Sewer Department.

Eric J. Pottenger
Development / Storm Water Manager
Direct: 513-785-4121 | Cell: 513-678-6325
Butler County Storm Water District
www.stormwaterdistrict.org

Butler County Engineer's Office
www.bceo.org
"Check out our new website!"